

Microscopic Analysis, Inc.

71 MEADOWLARK LANE
ST. LOUIS, MISSOURI 63146
(314) 993-2212

January 20, 1987


National Industrial Applicators, Inc.
5735 Fee Fee
St. Louis, Missouri 63042

Re: Bulk samples from GAF.

Gentlemen:

The bulk samples submitted for asbestos analysis on January 20, 1987, have been analyzed. The analysis for asbestos content was by Polarized Light Microscope (PLM) and Dispersion Staining (DS). The results of our analysis are contained below:

LABORATORY NUMBER	SAMPLE I.D./ LOCATION	ASBESTOS FOUND	PERCENT PRESENT
B-872148	#1 Boiler	Chrysotile	50-75%
B-872149	#2 Insulation on wall	No asbestos detected	N.A.
B-872150	#3 Ceiling	No asbestos detected	N.A.
B-872151	#4 Ductwork	No asbestos detected	N.A.



Douglas N. Nimmo, CIH
Director

DNN/kn

07KF

30290619

4.2



Superfund

0400